

WORKING CLEARANCES

SUFFICIENT ACCESS AND WORKING SPACE (SHADED AREA) SHALL BE PROVIDED AND MAINTAINED ABOUT ALL METERING EQUIPMENT TO PERMIT READY AND SAFE OPERATION AND MAINTENANCE OF SUCH EQUIPMENT. THE DIMENSION OF THE WORKING SPACE IN THE DIRECTION OF ACCESS TO LIVE PARTS OPERATING AT 600 VOLTS OR LESS AND LIKELY TO REQUIRE EXAMINATION, ADJUSTMENT SERVICING, OR MAINTENANCE WHILE ALIVE SHALL NOT BE LESS THAN 30" WIDE IN FRONT OF THE ELECTRIC EQUIPMENT. IN NO CASE SHALL HEADROOM BE LESS THAN 7'.

PLEASE DO NOT INSTALL OR STORE EQUIPMENT, PLANTS, ETC. WITHIN WORKING SPACE.

