

UNDERGROUND CURRENT TRANSFORMER METERING INSTALLATION (2001)

COOPERATIVE WILL:
INSTALL METER

FURNISH AND INSTALL CABLE,
C/T AND CONNECTIONS INSIDE OF
TRANSFORMER OR SECONDARY
ENCLOSURE

MEMBER WILL:
FURNISH & INSTALL METER BASE
FURNISH AND INSTALL ALL OTHER
REQUIRED MATERIALS. 1" PVC CONDUIT
AND PULL STRING TO BE FURNISHED BY
MEMBER FROM THE METER BASE TO THE
UNDERGROUND TRANSFORMER OR
PEDESTAL, INSTALL TRENCH & BACKFILL
SPECIAL ARRANGEMENTS WILL BE MADE
IF C/T CANNOT BE INSTALLED IN
TRANSFORMER SEE PAGE 43-46

